

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 01:11 pm

**PWS ID:** UTAH29009      **Name:** NORDIC MTN WATER COMPANY  
**Legal Contact:** NORDIC MTN WATER COMPANY      **Rating:** Approved  
 BILL D GREEN      **Rating Date:** 02/21/2002  
**Address:** PO BOX 897      **Activity Status:** Active  
 EDEN, UT 84310  
**Phone Number:** 801-745-3490  
**City Served (Area):**  
**County:** WEBER COUNTY  
**System Type:** Community      **Last Inv Update:** 05/28/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 10/22/2008      **Total Dsgn Cap:**  
**Population:** 509      **Surveyor:** FRANKLIN CARLSEN      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	GREEN, BILL D	ADMINISTRATC	801-791-3976		BILL.GREEN@NGC.COM

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	209
			209 Total Svc Connections

### Storage

**Total Storage:** 660,000 GAL      **Number of Units:** 3      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST003	STORAGE FACILITY ST003	Ground	500,000 GAL	Concrete		A	NO
ST001	STORAGE FACILITY ST001	Ground	70,000 GAL	Concrete		A	NO
ST002	STORAGE FACILITY ST002	Ground	90,000 GAL	Concrete		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NONEXISTENT WELL #1	Inactive	WL	12	35 GPM		Yes	GW	Other		
WS002	WELL #2	Active	WL	10	35 GPM	45 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	WELL #3	Active	WL	40	40 GPM	45 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS004	EMERGENCY WELL	Inactive	WL	6	30 GPM		Yes	GW	Emergency		
WS005	RHODES WELL	Active	WL		500 GPM	600 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.